

Maintaining High Standards

Once again we are proud to present our annual water quality report. This report covers all testing performed between January 1, 2009, and December 31, 2009. The events of the past few years have presented many of us with challenges we could not have imagined. Yet, in spite of this we have maintained our high standards in an effort to continue delivering the best quality drinking water possible. There may be other hurdles in the future, but know that we will always stand behind you and the drinking water we work diligently to provide.

We encourage you to share your thoughts with us on the information contained in this report. Should you ever have any questions, we are always available to assist you.

Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone



organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Disease

Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791 or www. epa.gov/safewater/hotline/.

Should I Put a Brick in My Toilet Tank to Save Water?

Toilet flushing uses a lot of water: about 40 percent of a household's total water usage. Putting something in the toilet tank that takes up space, like a toilet dam or a water filled jug, is a good idea. But putting a brick in the tank is not a good idea; bricks tend to crumble and might damage your toilet.

Substances That Could Be in Water

To ensure that tap water is safe to drink, the U.S. EPA prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, in some cases radioactive material, and substances resulting from the presence of animals or from human activity. Substances that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife;

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

Pesticides and Herbicides, which may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses;

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and may also come from gas stations, urban stormwater runoff, and septic systems;

Radioactive Contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.

For more information about contaminants and potential health effects, call the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

Where Does My Water Come From?

The City of Pineville Water Department customers are fortunate because they enjoy an abundant water supply from one source, the Carnahan Aquifer. The City has ten wells that pull from this aquifer. As a final step, our water is chlorinated for disinfection purposes prior to sending it into the distribution system and into your home or business.

What's a Cross-Connection?

Cross-connections that contaminate drinking water distribution lines are a major concern. A cross-connection is formed at any point where a drinking water line connects to equipment (boilers), systems containing chemicals (air conditioning systems, fire sprinkler systems, irrigation systems), or water sources of questionable quality. Cross-connection contamination can occur when the pressure in the equipment or system is greater than the pressure inside the drinking water line (backpressure). Contamination can also occur when the pressure in the drinking water line drops due to fairly routine occurrences (main breaks, heavy water demand) causing contaminants to be sucked out from the equipment and into the drinking water line (backsiphonage).

Outside water taps and garden hoses tend to be the most common sources of cross-connection contamination at home. The garden hose creates a hazard when submerged in a swimming pool or when attached to a chemical sprayer for weed killing. Garden hoses that are left lying on the ground may be contaminated by fertilizers, cesspools, or garden chemicals. Improperly installed valves in your toilet could also be a source of cross-connection contamination.

Community water supplies are continuously jeopardized by cross-connections unless appropriate valves, known as backflow prevention devices, are installed and maintained. We have surveyed all industrial, commercial, and institutional facilities in the service area to make sure that all potential cross-connections are identified and eliminated or protected by a backflow preventer. We also inspect and test each backflow preventer to make sure that it is providing maximum protection.

For more information, review the Cross-Connection Control Manual from the U.S. EPA's Web site at www. epa.gov/safewater/crossconnection.html. You can also call the Safe Drinking Water Hotline at (800) 426-4791.

Community Participation

You are invited to participate in our public forum and voice your concerns about your drinking water. We meet the second Tuesday of each month at 7 p.m. at City Hall, 910 Main Street, Pineville, La.

New Arsenic Regulation

A rsenic contamination of drinking water sources may result from either natural or human activities. Volcanic activity, erosion of rocks and minerals, and forest fires are natural sources that can release arsenic into the environment. Although about 90 percent of the arsenic used by industry is for wood preservative purposes, it is also used in paints, drugs, dyes, soaps, metals, and semiconductors. Agricultural applications, mining, and smelting also contribute to arsenic releases. Arsenic is usually found in the environment combined with other elements, such as oxygen, chlorine, and sulfur (inorganic arsenic) or carbon and hydrogen (organic arsenic). Organic forms are usually less harmful than inorganic forms.

Low levels of arsenic are naturally present in water – about 2 parts arsenic per billion parts of water (ppb). Thus, you normally take in small amounts of arsenic in the water you drink. Some areas of the country have unusually high natural levels of arsenic in rock, which can lead to unusually high levels of arsenic in water.

In January 2001, the U.S. EPA lowered the arsenic Maximum Contaminant Level (MCL) from 50 to 10 ppb in response to new and compelling research linking high arsenic levels in drinking water with certain forms of cancer. All water utilities were required to implement this new MCL in January 2006.

Removing arsenic from drinking water is a costly procedure but well worth the expenditure considering the health benefits. For a more complete discussion visit the U.S. EPA's arsenic Web site at www.epa.gov/safewater/arsenic.html.

Questions? (C)

For more information about this report, or for any questions relating to your drinking water, please call Kenneth Dubroc, Utilities Superintendent, at (318) 449-5688.

Sampling Results

uring the past year we have taken hundreds of water samples in order to determine the presence of any radioactive, biological, inorganic, volatile organic, or synthetic organic contaminants. The table below shows only those contaminants that were detected in the water. The state requires us to monitor for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

REGULATED SUBSTANCES	ES						
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	MCLG [MRDLG]	AMOUNT	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Alpha Emitters (pCi/L)	2005	15	0	4.0	NA	S _o	Erosion of natural deposits
Arsenic (ppb)	2005	01	0	0.001	NA	%	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Chlorine (ppm)	2009	[4]	[4]	1.30	1.22-1.37	No	Water additive used to control microbes
Fluoride (ppm)	2005	4	4	1.5	0.3–1.5	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Haloacetic Acids [HAA] ¹ (ppb)	2009	09	NA	QZ	NA	N _o	By-product of drinking water disinfection
TTHMs [Total Trihalomethanes] ² (ppb)	2009	80	NA	19.1	16.7–21.5	No No	By-product of drinking water chlorination
Tap water samples were collected for lead and copper analyses from sample sites throughout the community	for lead and co	pper analyse	s from sampl	e sites through	out the communi	ty	
SUBSTANCE YEAR (UNIT OF MEASURE) SAMPLED	AR PLED AL) WCLG	AMOUNT DETECTED (90TH% TILE)	SITES ABOVE AL/TOTAL SITES	VE L VIOLATION	N TYPICAL SOURCE	SOURCE
Copper (ppm) 20	2008 1.3	1.3	0.1	0/30	Š	Corrosic deposits	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb) 20	2008 15	0	7	0/30	%	Corrosic deposits	Corrosion of household plumbing systems; Erosion of natural deposits
OTHER REGULATED SUBSTANCES	BSTANCES						
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	MCLG [MRDLG]	AMOUNT	RANGE LOW-HIGH	VIOLATION	SAMPLE SITE
Haloacetic Acids [HAA] (ppb)	2009	09	NA	25.5	ND-25.5	S _o	DBP RULE-JANET DRIVE
Total Trihalomethanes [TTHM] (ppb)	2009	80	NA	38.4	5.5-38.4	No	DBP RULE-NORA STREET

¹The detected amount is the LRAA for HAA5 Bayou Marie Stage 1 DBP Rule site.

Definitions

AL (Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable.

ND (Not detected): Indicates that the substance was not found by laboratory analysis.

pCi/L (picocuries per liter): A measure of radioactivity.

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

ppm (parts per million): One part substance per million parts water (or milligrams per liter).

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.

²The detected amount is the LRAA for TTHM Bayou Marie Stage 1 DBP Rule site.

Tap vs. Bottled

Thanks in part to aggressive marketing, the bottled water industry has successfully convinced us all that water purchased in bottles is a healthier alternative to tap water. However, according to a four-year study conducted by the Natural Resources Defense Council, bottled water is not necessarily cleaner or safer than most tap water. In fact, about 25 percent of bottled water is actually just bottled tap water (40 percent according to government estimates).

The Food and Drug Administration is responsible for regulating bottled water, but these rules allow for less rigorous testing and purity standards than those required by the U.S. EPA for community tap water. For instance, the high mineral content of some bottled waters makes them unsuitable for babies and young children. Further, the FDA completely exempts bottled water that's packaged and sold within the same state, which accounts for about 70 percent of all bottled water sold in the United States.

People spend 10,000 times more per gallon for bottled water than they typically do for tap water. If you get your recommended eight glasses a day from bottled water, you could spend up to \$1,400 annually. The same amount of tap water would cost about 49 cents. Even if you installed a filter device on your tap, your annual expenditure would be far less than what you'd pay for bottled water.

For a detailed discussion on the NRDC study results, check out their Web site at www.nrdc.org/water/drinking/bw/exesum.asp.

What's Your Water Footprint?

You may have some understanding about your carbon footprint, but how much do you know about your water footprint? The water footprint of an individual, community, or business is defined as the total volume of freshwater that is used to produce the goods and services that are consumed by the individual or community or produced by the business. For example, 11 gallons of water are needed to irrigate and wash the fruit in one half-gallon container of orange juice. Thirty-seven gallons of water are used to grow, produce, package, and ship the beans in that morning cup of coffee. Two hundred and sixty-four gallons of water are required to produce one quart of milk, and 4,200 gallons of water are required to produce two pounds of beef.



According to the U.S. EPA, the average American uses about 100 gallons of water daily. In fact, in the developed world, one flush of a toilet uses as much water as the average person in the developing world allocates for an entire day's cooking, washing, cleaning, and drinking. The annual American per capita water footprint is about 8,000 cubic feet; twice the global per capita average. With water use increasing six-fold in the past century, our demands for freshwater are rapidly outstripping what the planet can replenish.

To check out your own water footprint, go to www.h2oconserve.org, or visit www.waterfootprint.org to see how the water footprints of other nations compare.

What Are PPCPs?

When cleaning out your medicine cabinet, what do you do with your expired pills? Many people flush them down the toilet or toss them into the trash. Although this seems convenient, these actions could threaten our water supply.

Recent studies are generating a growing concern over pharmaceuticals and personal care products (PPCPs) entering water supplies. PPCPs include human and veterinary drugs (prescription or over-the-counter) and consumer products, such as cosmetics, fragrances, lotions, sunscreens, and house cleaning products. Over the past five years, the number of U.S. prescriptions increased 12 percent to a record 3.7 billion, while nonprescription drug purchases held steady around 3.3 billion. Many of these drugs and personal care products do not biodegrade and may persist in the environment for years.

The best and most cost-effective way to ensure safe water at the tap is to keep our source waters clean. Never flush unused medications down the toilet or sink. Instead, check to see if the pharmacy where you made your purchase accepts medications for disposal, or contact your local health department for information on proper disposal methods and drop-off locations. You can also go on the Web at www.Earth911.com to find more information about disposal locations in your area.

How Long Can I Store Drinking Water?

The disinfectant in drinking water will eventually dissipate even in a closed container. If that container housed bacteria prior to filling up with the tap water, the bacteria may continue to grow once the disinfectant has dissipated. Some experts believe that water could be stored up to six months before needing to be replaced. Refrigeration will help slow the bacterial growth.

MTBE in the News

TBE (Methyl tert-Butyl Ether) belongs to a group of chemicals commonly known as fuel oxygenates. Oxygenates are added to gasoline to reduce carbon monoxide and ozone levels in the air caused by auto emissions.

MTBE contamination of drinking water sources may result from leaking fuel storage tanks, pipelines, refueling spills, consumer disposal of old gasoline, emissions from older marine engines, and to a lesser degree, stormwater runoff and precipitation mixed with MTBE in the air. Currently, the primary concern about MTBE in drinking water is that it causes taste and odor problems. There are no data showing significant health risks of MTBE at low-exposure levels in drinking water; however, it is a potential human carcinogen at high doses. In December 1997, the U.S. EPA issued a drinking water advisory stating that it is unlikely that MTBE in drinking water at concentrations of 20 to 40 ppb will cause adverse health effects. Continuing research by the U.S. EPA and others is expected to help determine more precisely the potential for adverse health effects from MTBE in drinking water.

In an effort to better balance the air-quality benefits and water-quality concerns associated with oxygenates in gasoline, the U.S. EPA now requires reducing or eliminating MTBE as a fuel oxygenate. Also, the agency is considering setting health standards for MTBE and is currently gathering information from utilities across the country on the occurrence of MTBE. For a more complete discussion, visit the U.S. EPA's MTBE Web site at www.epa.gov/mtbe/faq.htm.

Lead and Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Pineville is responsible for providing high-quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/ lead.